

**Oceana County Building Department
2023 Michigan Electrical Code**

**Residential Code Change
Effective March 12, 2024**

R230.25 Emergency Disconnects:

(A) For 1 and 2 family dwelling units, an emergency disconnecting means shall be installed.

(1) Location:

The disconnecting means shall be installed in a readily accessible outdoor location on the dwelling unit.

(2) Grouping:

If more than one (1) disconnecting means are required, they shall be grouped.

(3) Disconnects:

Each disconnect shall be service disconnect rated.

(4) Service Replacements:

Service replacements or upgrades shall comply with R230.25 (A) and (B)

(B) Marking:

The service disconnecting means shall be marked as follows.

EMERGENCY DISCONNECT, SERVICE DISCONNECT